

2022 Annual Drinking Water Consumer Confidence Report
Town of Enterprise
PWS ID # 0120004

Report Completed on May 24, 2023

We're pleased to present to you your 2022 Annual Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

Sources of Water

Our water source consists of 2 wells that draw from the Lower Wilcox Aquifer.

Water System Information

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. Our water supply received a lower susceptibility ranking to contamination.

The quality of the water from our system is far better than any bottled water you can find. We test daily and maintain a good chlorine residual to keep the water safe as it comes through the distribution lines to the customer's faucet. The cost for maintaining the water system is budgeted each year after looking at the expense of the previous year and considering rising costs of maintenance. We are currently operating at a budget of \$216,600. This covers routine maintenance, chemicals, repairs, parts, and personnel that are on call 24 hours a day, 7 days a week. This past year we cleaned and repainted the water storage tank as recommended by MSDH. The cost of this project was \$89,094. Funds from the American Rescue Plan Act were used to pay for this expense. The painting of the tank is not an annual expense and is done on an average of every 10 years.

If you have any questions about this report or concerning your water utility, please contact Randy Freeman at 601-479-9524. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the 1st Tuesday of each month at Enterprise Town Hall at 6:00 pm.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31, 2022. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

CONTAMINANT TABLE

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	MCLG	MCL	Major Sources in Drinking Water
Inorganic Contaminants							
13. Barium	N	2022	0.0113 ppm	No Range	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
20. Chromium	N	2022	0.6 ppb	No Range	100	100	Discharge from steel and pulp mills; erosion of natural deposits
21. Copper	N	1/1/19 to 12/31/21*	0.6 ppm	None	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
24. Lead	N	1/1/19 to 12/31/21*	1.0 ppb	None	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Volatile Organic Contaminants							
73. Ethylbenzene	N	2022	1.55 ppb	No Range	700	700	Discharge from petroleum refineries
82. Xylenes	N	2022	0.01079 ppm	No Range	10	10	Discharge from petroleum factories; discharge from chemical factories
Disinfectants & Disinfectant By-Products							
83. Chlorine	N	2022	0.90 ppm	0.56 to 1.03	4	4	Water additive used to control microbes
84. Haloacetic Acids HAA5	N	2022	11.1 ppb	3.4 to 11.1	0	60	By-product of drinking water disinfection
85. TTHM [Total trihalomethanes]	N	2022	24.3 ppb	11 to 24.3	0	80	By-product of drinking water disinfection

* Most recent sample results available

Definitions

In the table above you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:
Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.
Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
ppb - parts per billion = micrograms per liter (= 1 drop in 1 billion gallons)
ppm - parts per million = milligrams per liter (= 1 drop in 1 million gallons)

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or

cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

Additional Information

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health care provider.

EPA is reviewing the drinking water standard for arsenic because of special concerns that it may not be stringent enough. Arsenic is a naturally occurring mineral known to cause cancer in humans at high concentrations.

The average household uses approximately 400 gallons of water per day. There are many low cost and no-cost ways to conserve water. Small changes can make a big difference - try one today and soon it will become second nature.

- ▶ Take short showers - a 5 minute shower uses 4 to 5 gallons of water compared to 50 gallons for a bath.
- ▶ Shut off water while brushing your teeth, washing your hair and shaving and save up to 500 gallons a month.
- ▶ Use a water-efficient showerhead. They are inexpensive, easy to install and can save you up to 750 gallons a month.
- ▶ Run your clothes wash and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- ▶ Water plants only when necessary.
- ▶ Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- ▶ Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.
- ▶ Teach your children about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- ▶ Visit www.epa.gov/watersense for more information.

This report is being published in the paper and will not be mailed. Please call our office if you have any questions.